

## Public Notice of Acceptance of Conditional Early Settlement Offer for Mandatory Minimum Penalties

### Conditional Early Settlement Offer No. SWB-2008-3-0002 with Mandatory Minimum Penalties against California Water Service

On July 1, 2008, the State Water Resources Control Board (State Board) issued Offer to Participate in Expedited Payment Program No. SWB-2008-3-0002 to California Water Service for alleged violations of Regional Board Order No. R3-2006-0063, NPDES Permit No. CAG993001 for Cal Water Stations 64, 67, 69, 40-01. On January 7, 2009, California Water Service accepted the State Board's offer to participate in the Expedited Payment Program and Waived their right to a hearing. The following table lists this facility's alleged violations of subdivisions (h) and (i) of California Water Code section 13385, from January 1, 2000 through March 31, 2008, which have not received mandatory minimum penalty assessments by the Water Boards. Final calculation of MMP amounts owed is also listed below.

Violation ID	Occurred Date	Type	MMP Type	Violation Description
640935	5/7/2007	CAT2	SIG	Station 64 - Chlorine residual violation; permit limit of 0.02 mg/L; reported value of 0.04 mg/L.
640936	5/8/2007	CAT2	SIG	Station 64 - Chlorine residual violation; permit limit of 0.02 mg/L; reported value of 0.05 mg/L.

Mandatory Minimum Penalty Amount Owed for Effluent Violations  
(2 Serious Violations + 0 Chronic Violations) × \$3,000 = \$6,000 to the Cleanup & Abatement Account

Written comments regarding the Expedited Payment Program and Waiver will be accepted through May 6, 2009. For more information, please contact Taryn Stokell at (916) 327-8039.

### Conditional Early Settlement Offer No. SWB-2008-3-0003 with Mandatory Minimum Penalties against Carpinteria Sanitary District

On July 1, 2008, the State Water Resources Control Board (State Board) issued Offer to Participate in Expedited Payment Program No. SWB-2008-3-0003 to Carpinteria Sanitary District for alleged violations of Regional Board Order No. R3-2005-0110, NPDES Permit No. CA0047364 for Carpinteria SD WWTP. On July 15, 2008, Carpinteria Sanitary District accepted the State Board's offer to participate in the Expedited Payment Program and Waived their right to a hearing. The following table lists this facility's alleged violations of subdivisions (h) and (i) of California Water Code section 13385, from January 1, 2000 through December 31, 2007, which have not received mandatory minimum penalty assessments by the Water Boards. Final calculation of MMP amounts owed is also listed below.

Violation ID	Occurred Date	Type	MMP Type	Violation Description
451356	8/19/2006	CAT1	CHRON	Total suspended solids violation; permit limit of 45 mg/L; reported value of 57.25 mg/L.
451354	8/15/2006	CAT1	SIG	Total suspended solids violation; permit limit of 45 mg/L; reported value of 77 mg/L.
451355	8/16/2006	CAT1	SIG	Total suspended solids violation; permit limit of 45 mg/L; reported value of 71.67 mg/L.

Mandatory Minimum Penalty Amount Owed for Effluent Violations  
(2 Serious Violations + 1 Chronic Violation) × \$3,000 = \$9,000 to the Cleanup & Abatement Account

Written comments regarding the Expedited Payment Program and Waiver will be accepted through May 6, 2009. For more information, please contact Taryn Stokell at (916) 327-8039.

**Conditional Early Settlement Offer No. SWB-2008-3-0011 with Mandatory Minimum Penalties against City of Paso Robles**

On July 1, 2008, the State Water Resources Control Board (State Board) issued Offer to Participate in Expedited Payment Program No. SWB-2008-3-0011 to the City of Paso Robles for alleged violations of Regional Board Order No. R3-2004-0031, NPDES Permit No. CA0047953 for City of Paso Robles WWTP. On October 13, 2008, the City of Paso Robles accepted the State Board's offer to participate in the Expedited Payment Program and Waived their right to a hearing. The following table lists this facility's alleged violations of subdivisions (h) and (i) of California Water Code section 13385, from January 1, 2000 through December 31, 2007, which have not received mandatory minimum penalty assessments by the Water Boards. Final calculation of MMP amounts owed is also listed below.

Violation ID	Occurred Date	Type	MMP Type	Violation Description
428628	6/8/2006	CAT1	CHRON	Sodium violation; reported value of 230 mg/L, limit = 225 mg/L.
437809	8/3/2006	CAT1	CHRON	Non-compliant result was: 230 mg/L
439163	8/16/2006	OEVI	CHRON	Total coliform violation; permit limit of 2300 MPN/ 100 mL; reported value of 5000 MPN/ 100 mL.
439758	9/7/2006	CAT1	CHRON	Non-compliant result was: 230 mg/L
493233	12/6/2006	CAT1	CHRON	Effluent sodium violation; permit limit of 225 mg/L; reported value of 240 mg/L.
566484	4/10/2007	CAT1	CHRON	Effluent sodium violation; permit limit of 225 mg/L; reported value of 230 mg/L.
566480	4/26/2007	OEVI	CHRON	Effluent total coliform violation; permit limit of 2300 MPN/ 100 mL; reported value of 2800 MPN/ 100 mL.
634631	6/7/2007	CAT1	CHRON	Effluent sodium violation; permit limit of 225 mg/L; reported value of 230 mg/L.
634670	7/3/2007	CAT1	CHRON	Sodium violation; permit limit of 225 mg/L; reported value of 255 mg/L.
634668	7/11/2007	CAT1	CHRON	Bis (2- Ethylhexyl) Phthalate violation; permit limit of 5.0 ug/L; reported value of 5.3 ug/L.
694370	9/11/2007	CAT1	CHRON	Effluent sodium violation; permit limit of 225 mg/L; reported value of 255 mg/L.
711674	11/6/2007	CAT1	CHRON	Sodium violation; permit limit of 225 mg/L; reported value of 240 mg/L.
493237	1/9/2007	CAT2	SIG	Effluent unionized ammonia violation; permit limit of 0.025 mg/L; reported value of 0.078 mg/L.

Mandatory Minimum Penalty Amount Owed for Effluent Violations

(1 Serious Violation + 12 Chronic Violations) × \$3,000 = \$39,000 to the Cleanup & Abatement Account

Written comments regarding the Expedited Payment Program and Waiver will be accepted through May 6, 2009. For more information, please contact Taryn Stokell at (916) 327-8039.

**Conditional Early Settlement Offer No. SWB-2008-3-0013 with Mandatory Minimum Penalties against City of Pismo Beach**

On July 1, 2008, the State Water Resources Control Board (State Board) issued Offer to Participate in Expedited Payment Program No. SWB-2008-3-00013 to the City of Pismo Beach, for alleged violations of Regional Board Order No. R3-2004-0051, NPDES Permit No. CA0048151 for Pismo Beach WWTP. On November 20, 2008, the City of Pismo Beach accepted the State Board's offer to participate in the Expedited Payment Program and Waived their right to a hearing. The following table lists this facility's alleged violations of subdivisions (h) and (i) of California Water Code section 13385, from January 1, 2000 through December 31, 2007, which have not received mandatory minimum penalty assessments by the Water Boards. Final calculation of MMP amounts owed is also listed below.

Violation ID	Occurred Date	Type	MMP Type	Violation Description
299196	2/3/2005	OEV	CHRON	Seven-day median fecal coliform violation; permit limit is 200 MPN and reported value is 220 MPN.
299197	2/4/2005	OEV	CHRON	Seven-day median fecal coliform violation; permit limit is 200 MPN and reported value is 240 MPN.
299204	2/4/2005	OEV	CHRON	Daily max fecal coliform violation; permit limit is 2000 MPN and reported value is 50,000 MPN.
299198	2/7/2005	OEV	CHRON	Seven-day median fecal coliform violation; permit limit is 200 MPN and reported value is 240 MPN.
299199	2/8/2005	OEV	CHRON	Seven-day median fecal coliform violation; permit limit is 200 MPN and reported value is 220 MPN.
299200	2/9/2005	OEV	CHRON	Seven-day median fecal coliform violation; permit limit is 200 MPN and reported value is 220 MPN.
299201	2/10/2005	OEV	CHRON	Seven-day median fecal coliform violation; permit limit is 200 MPN and reported value is 240 MPN.
299202	2/11/2005	OEV	CHRON	Seven-day median fecal coliform violation; permit limit is 200 MPN and reported value is 300 MPN.
299203	2/14/2005	OEV	CHRON	Seven-day median fecal coliform violation; permit limit is 200 MPN and reported value is 300 MPN.
299205	2/11/2005	OEV	CHRON	Daily max fecal coliform violation; permit limit is 2000 MPN and reported value is 30,000 MPN.
299207	4/13/2005	OEV	CHRON	Daily max fecal coliform violation; permit limit is 2000 MPN and reported value is 2200 MPN.
422587	5/31/2006	OEV	CHRON	Effluent fecal coliform violation; reported value of 240 MPN/ 100mL.

**Mandatory Minimum Penalty Amount Owed for Effluent Violations**

(0 Serious Violations + 12 Chronic Violations) × \$3,000 = \$36,000 to the Cleanup & Abatement Account

Written comments regarding the Expedited Payment Program and Waiver will be accepted through May 6, 2009. For more information, please contact Taryn Stokell at (916) 327-8039.

**Conditional Early Settlement Offer No. SWB-2008-3-0017 with Mandatory Minimum Penalties against San Simeon Community Services District**

On July 1, 2008, the State Water Resources Control Board (State Board) issued Offer to Participate in Expedited Payment Program No. SWB-2008-3-0017 to San Simeon Community Services District for alleged violations of Regional Board Order No. R3-2002-0046, NPDES Permit No. CA0047961 for San Simeon WWTP. On November 13, 2008, San Simeon Community Services District accepted the State Board's offer to participate in the Expedited Payment Program and Waived their right to a hearing. The following table lists this facility's alleged violations of subdivisions (h) and (i) of California Water Code section 13385, from January 1, 2000 through December 31, 2007, which have not received mandatory minimum penalty assessments by the Water Boards. Final calculation of MMP amounts owed is also listed below.

Violation ID	Occurred Date	Type	MMP Type	Violation Description
458879	11/11/2006	CAT2	CHRON	Chlorine residual violation; permit limit of 0.93 mg/L; reported value of 1.04 mg/L/

**Mandatory Minimum Penalty Amount Owed for Effluent Violations**

(0 Serious Violations + 1 Chronic Violation) × \$3,000 = \$3,000 to the Cleanup & Abatement Account

Written comments regarding the Expedited Payment Program and Waiver will be accepted through May 6, 2009. For more information, please contact Taryn Stokell at (916) 327-8039.